



STATUS REFERENCE

STATUS	WHAT YOU SEE	WHAT TO DO	PRODUCT	RESULT
Normal	Everything normal	Keep dosing	Cleanpower	System stays clean
Warning	Pumps starting to slow	Start treatment	Cleanpower	Flow improves gradually
Warning	Brown residue in filters	Start treatment	Cleanpower	Prevents buildup getting worse
Warning	Flow inconsistent	Continue + monitor	Cleanpower	Stabilises system
Severe	Heavy blockage	Escalate treatment	Cleanpower → PMX145	Recovery
Severe	Filters keep blocking	Clean system	PMX145	System resets
Contamination	Water present	Remove + treat	Kathon 15	Eliminates contamination
No Improvement	No improvement	Call technician	—	Mechanical issue

STATUS LEGEND

Normal System operating as expected	Warning Action required — monitor closely	Severe Immediate escalation needed	Contamination Contamination detected	No Improvement Escalate to technician
---	---	--	--	---

PRODUCT NOTES

- **Cleanpower** — Standard preventative and maintenance dose for ongoing fuel system health.
- **PMX145** — Heavy-duty treatment for severe blockage recovery; use after Cleanpower escalation.
- **Kathon 15** — Biocide treatment; removes microbial contamination and water-related issues.